

NOTES AND SPECIFICATIONS

GENERAL ENGINEERING NOTES

1. ALL MATERIAL AND WORKMANSHIP MUST COMPLY WITH THE REQUIREMENTS OF THE LATEST RELEVANT SABS REQUIREMENTS.

2. ALL DIMENSIONS ARE IN MILLIMETRES, (UNLESS OTHERWISE SPECIFIED)

3. DO NOT SCALE FROM THESE DRAWINGS.

4. ALL DIMENSIONS MUST BE CHECK AND APPROVED ON SITE.

5. THE CONSTRUCTION TO BE DONE IN ACCORDANCE WITH THE STANDARD SPECIFICATION FOR MUNICIPAL CIVIL ENGINEERING WORKS, THIRD EDITION 2005 AND THE STANDARD CTWW DETAIL DRAWINGS.

6. THESE DRAWINGS MUST BE READ IN CONJUNCTION WITH THE STANDARD DRAWINGS (IF APPLICABLE).

7. THESE DRAWINGS MUST BE READ IN CONJUNCTION WITH THE STANDARD SPECIFICATIONS FOR MUNICIPAL CIVIL ENGINEERING WORKS, SERIES 4.

8. THE SIGNATURE OR INITIALS ON THIS DRAWING, OF ANY MANAGER OF WATER AND SANITATION AND INFRASTRUCTURE DEVELOPMENT DEPARTMENT, IN NO WAY REMOVES ANY RESPONSIBILITY WHATSOEVER FROM THE CONSULTANT.

9. THE CONSULTANT REMAINS RESPONSIBLE TO ENSURE THAT ALL THE GUIDELINES, STANDARD DRAWINGS, STANDARDS AND SPECIFICATIONS OF WATER AND SANITATION AND INFRASTRUCTURE DEVELOPMENT DEPARTMENT HAVE BEEN MET AND COMPLIED WITH.

10. FINAL POSITION OF SERVICES TO BE DETERMINED ON SITE.

LEGEND

SITE BOUNDARY FENCE

ERF BOUNDARY

OUTFALL SEWER

EXISTING SEWER

RISING MAIN

SEWER NOTES:

1. PRECAST CONCRETE MANHOLES AND SLABS ARE TO COMPLY WITH SABS 1284 (1993)

2. PIPE SECTIONS AND SLABS ARE TO BE BEDDED ON A 2:1 CEMENT MORTAR GROUT TO FORM A COMPACTED WATER TIGHT JOINT OF APPROXIMATELY 5 mm.

3. MANHOLE SHAFTS ARE TO BE PLACED OVER THE LARGEST LANDING ON THE DOWN STREAM SIDE.

4. STEPS TO BE LOCATED OVER LARGEST LANDING ON DOWN STREAM SIDE.

5. MANHOLE COVER AND FRAMES TO BE HEAVY DUTY PRECAST CONCRETE COVER WITH STEEL LIP RING AND FRAME.

6. THE MAXIMUM PROTRUSION OF PIPES INTO MANHOLES TO BE 50mm.

7. CHANNEL INSERTS BETWEEN STANDARD FITTINGS TO BE 100mm MINIMUM.

8. THE VERTICAL DISTANCE BETWEEN STEP IRONS IS 250 mm + or - 12 mm. THE HORIZONTAL DISTANCE BETWEEN THE CENTRES OF THE TREADS IS 150mm + or - 12mm.

9. ALL PIPES AND FITTINGS TO BE uPVC HEAVY DUTY CLASS 34 AND COMPLY WITH SABS 791.

10. ALL CONNECTIONS TO BE CAPPED BEFORE BACKFILLING AND TO BE WIRE MARKED.

11. ALL PIPES, FITTINGS TO SABS 559 (1993), AS AMENDED.

12. ALL CONCRETE TO BE 15MPa AS PER SABS 1200 (1982).

13. THE MINIMUM GRADE OF THE SEWER CONNECTION IS TO BE 1 IN 60.

14. IN ALL CASES THE JUNCTION INTO THE MAIN SEWER IS TO BE ENCASED.

15. INVERT OF CONNECTION TO CONNECT TO SOFFIT OF SEWER.

16. FOR SEWER LONGITUDINAL SECTIONS SEE DRG. No. CH061152 AND S3.

17. ALL WORK AND FREQUENCY OF TESTING TO COMPLY WITH SABS 1200 D.

18. SETTING OUT DIMENSIONS AND LEVELS TO BE CONFIRMED ON SITE PRIOR TO CONSTRUCTION.

19. ANY DISCREPANCIES TO BE REPORTED TO THE ENGINEER.


20. ALL INTERNAL SEWER PIPES TO BE 1600 uPVC ON SELECTED GRANULAR MATERIAL.

IF IN DOUBT ASK

REVISION INFORMATION

No.	DATE	DESCRIPTION:	BY
E1	2022-06-07	ISSUED FOR DETAIL DESIGN	S.H
F1	2023-09-21	ISSUED FOR TENDER	N.M

CLIENT



Housing Development Agency
BLOCK B, MILLENNIUM BUILDING
89 BICCARD STREET
POLOKWANE
LIMPOPO

CONSULTANT



AMCE
20 BAVARIA AVE.
MIDRAND
1685
WEB: www.amce.co.za
TELL: (011) 312 1599

PROJECT DESCRIPTION

BURGERSFORT EXT 54,
EXT 58, EXT 71 & 72

DISCIPLINE

ROADS DEPARTMENT

DRAWING DESCRIPTION

BURGERSFORT EXT 54,
SITE PLAN LAYOUT

DRAWN BY: S.IHLONGWANA	SIGNATURE AND DATE: 21 SEP 2023
REVIEWED BY: M. TSOAI Pr Eng: 20160198	SIGNATURE AND DATE: 21 SEP 2023
APPROVED BY: M. GWABA Pr Eng: 20140479	SIGNATURE AND DATE: 21 SEP 2023
PROJECT NO 1121	DATE 21 SEP 2023

DRAWING NO
NT06-22-1121-100-PS-004

SCALE AS SHOWN	SHEET SIZE A0	REVISION F1
-------------------	------------------	----------------



LOCALITY PLAN
SCALE 1:10 000

